

City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - June, 2024

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	Bypass Target Flow (cfs)	70% of Bypass Target Flow (cfs)	Bypass Actual Flow (cfs)	3-day Average Bypass Actual Flow (cfs)	3-day Average Bypass Target Flow (cfs)	Reservoir Spilling (yes/no)
5	31	580.57	0.38	0.25	0.18	0.265	0.28	0.25	No
6	1	580.53	0.36	0.23	0.16	0.224	0.26	0.24	No
6	2	580.48	0.34	0.22	0.15	0.245	0.24	0.23	No
6	3	580.43	0.32	0.20	0.14	0.235	0.23	0.22	No
6	4	580.38	0.30	0.19	0.13	0.217	0.23	0.20	No
6	5	580.33	0.29	0.18	0.13	0.211	0.22	0.19	No
6	6	580.27	0.26	0.17	0.12	0.196	0.21	0.18	No
6	7	580.21	0.25	0.16	0.11	0.197	0.20	0.17	No
6	8	580.15	0.23	0.15	0.11	0.189	0.19	0.16	No
6	9	580.10	0.21	0.14	0.10	0.162	0.18	0.15	No
6	10	580.06	0.21	0.13	0.09	0.145	0.17	0.14	No
6	11	580.00	0.20	0.13	0.09	0.145	0.15	0.13	No
6	12	579.94	0.18	0.12	0.08	0.149	0.15	0.13	No
6	13	579.88	0.17	0.11	0.08	0.123	0.14	0.12	No
6	14	579.82	0.17	0.10	0.07	0.119	0.13	0.11	No
6	15	579.75	0.13	0.10	0.07	0.106	0.12	0.10	No
6	16	579.68	0.13	0.08	0.06	0.105	0.11	0.09	No
6	17	579.60	0.11	0.08	0.06	0.089	0.10	0.09	No
6	18	579.53	0.10	0.07	0.05	0.096	0.10	0.08	No
6	19	579.47	0.09	0.06	0.04	0.074	0.09	0.07	No
6	20	579.39	0.08	0.05	0.04	0.100	0.09	0.06	No
6	21	579.34	0.09	0.05	0.04	0.072	0.08	0.05	No
6	22	579.29	0.11	0.05	0.04	0.059	0.08	0.05	No
6	23	579.24	0.10	0.07	0.05	0.049	0.06	0.06	No
6	24	579.18	0.09	0.06	0.04	0.070	0.06	0.06	No
6	25	579.13	0.09	0.05	0.04	0.066	0.06	0.06	No
6	26	579.07	0.07	0.05	0.04	0.058	0.06	0.05	No
6	27	579.01	0.05	0.04	0.03	0.055	0.06	0.05	No
6	28	578.95	0.04	0.03	0.02	0.046	0.05	0.04	No
6	29	578.89	0.04	0.02	0.01	0.046	0.05	0.03	No
6	30	578.84	0.05	0.02	0.01	0.026	0.04	0.02	No

Total Monthly Target: 2,009,906 gallons

Total Monthly Actual: 2,372,432 gallons